


| Key | |
|-----|---------------------------------|
| | Site Boundary |
| | HV Cable Route - Trench |
| | AC/DC Cable Route (Tray/Ladder) |
| | Security Fence |
| | Access Route |
| | Concrete Base |
| | Access Path / Hardstanding |
| | Customer Substation |
| | DNO Substation |
| | MV Station |
| | Battery Container |
| | Gates |

TOTAL SITE

Battery Block 4x2580kWh (10320kWh) = 6
 PCS Units 2x2500kW (5000kVA) = 6
 Transformers (5000kVA) = 6
 System Size = 30.00MW/61.92MWh



| Revision | Description | Revised By | Date | Drawn By |
|----------|--------------------------------------|------------|------------|----------|
| A | Revised from Drawing no. Q21_0305_02 | MS | 27/03/2022 | JH |
| B | Several amendments | DM | 18/11/2022 | |
| C | Revised to Sungrow 2h solution | DM | 22/11/2022 | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

| | | |
|--|-------------|-------------|
| Installation Address | | Project |
| Househill, Naim, Highland, IV12 5HY | | Naim |
| Title | | Site Layout |
| Drawing No. | C0002472_02 | Rev. C |

| | |
|--|--|
| Comments | |
| Total area of site: 8.29 Acres / 3.35 hectares | |



Inhiber Details
 Anesco Ltd.
 The Green,
 Easter Park,
 Benyon Road,
 Reading,
 RG7 2PQ
 Tel: 0845 894 4444